



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-07/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	17/01567 PNKT DISPENSER TANK	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW / FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(12+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
TK/11/215/006/01/TANK1 SCS 1 R2 (N-75 / WN-192)	15	3	—	12	16 - 17	NRI	Accept	

End of Report

Legend:

TI Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 15 April 2018



Client Representative:

Name:
Date:



Our Ref.: NT/103519/18-09

Page No: 1 of 1
 Report No: NDT/RT/180405-07/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	17/01567 PNKT DISPENSER TANK	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(12+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
TK/11/215/006/01/TANK1								
SLS 4 R2 (WN-92)	15	3	-	12	1-2	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer :	Emirsham - NDT Lev. II	Client Representative:	
Interpreted & Evaluated By:	Amat Hamidi - NDT Lev. II	Name:	
Date:	15 April 2018	Date:	





NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 9, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-04/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01668PCYC Premium Vegetable Oil Sdn. Bhd.	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(6+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
(07.29.01)								
LS 2a R2 (WN-31)	9	3	-	6	0 - 1	Per	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev. II

Date: 15 April 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-05/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01668PCYC Premium Vegetable Oil Sdn. Bhd.	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(6+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
(07.29.01)								
LS 2b R2 (WN-31)	9	3	-	6	0 - 1	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref.: NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-07/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01669PCYC Premium Vegetable Oil Sdn. Bhd.	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(6+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
(07.29.01)								
LS 2 R2 (WN-31)	9	3	-	6	3-4	Con	Accept	

End of Report

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref.: NT/103519/18-09

Page No: 1 of 1
 Report No: NDT/RT/180405-06/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Soremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01669PCYC Premium Vegetable Oil Sdn. Bhd.	IQI type :	ASTM 1A
Material:	SA 240 Gr.304/304L	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	14 April 2018	Source Side of Object to Film Distance:	(6+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
(07.29.01)								
LS 5 R2 (WN-31)	9	3	—	6	2-3	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev. II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-03/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Soremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01728PCYC	IQI type :	ASTM 1A
	Sludge Filter No.1 (222/001/1)	Film Manufacturer/Type :	FUJI 100(class II)
	Venator (Tank 1)	Density :	2.0-3.5
Material:	S 275 JR	Sensitivity:	0.20mm(2 wires visible)
		Source to Object Distance :	400mm
Welding Process :	FCAW	Source Side of Object to Film Distance:	(6+3)mm
Examination Code :	ASME V	No of Radiograph(exposure) :	Single Exposure
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
Examination Date:	14 April 2018	Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
Sludge Filter No.1 (222/001/1)								
Joint 2 (WN-119)	9	3	-	6	0 - 1	Uc	Reject	
					1 - 2	SI	Reject	
					2 - 3	Por / LF	Accept	AR
					3 - 4	Por / Uc	Accept	
					4 - 5	Por / Uc	Reject	
					5 - 6	Uc	Reject	

End of Report

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref.: NT/103519/18-09

Page No: 1 of 1

Report No: NDT/RT/180405-02/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Soremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01728PCYC	IQI type :	ASTM 1A
	Sludge Filter No.1 (222/001/1)	Film Manufacturer/Type :	FUJI 100(class II)
	Venator (Tank 1)	Density :	2.0-3.5
Material:	S 275 JR	Sensitivity:	0.20mm(2 wires visible)
		Source to Object Distance :	400mm
Welding Process :	FCAW	Source Side of Object to Film Distance:	(6+3)mm
Examination Code :	ASME V	No of Radiograph(exposure) :	Single Exposure
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
Examination Date:	14 April 2018	Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks	
Sludge Filter No.1 (222/001/1)									
Joint 4 (WN-119)	9	3	-	6	0 - 1	Uc	Accept		
						1 - 2	SI	Reject	
						2 - 3	Por / LF	Reject	
						3 - 4	Por / Uc	Accept	
						4 - 5	Por / Uc	Accept	
						5 - 6	Uc	Accept	
						6 - 7	SI / Por	Reject	
						7 - 8	SI / Por	Reject	

End of Report

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref.: NT/103519/18-09

Page No: 1 of 2

Report No: NDT/RT/180405-01/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Seremban Engineering Berhad	Procedure No:	NT/RT/ASME REV 7.0
Project :	18/01728PCYC	IQI type :	ASTM 1A
	Sludge Filter No.1 (222/001/1)	Film Manufacturer/Type :	FUJI 100(class II)
	Venator (Tank 1)	Density :	2.0-3.5
Material:	S 275 JR	Sensitivity:	0.20mm(2 wires visible)
		Source to Object Distance :	400mm
Welding Process :	FCAW	Source Side of Object to Film Distance:	(6+3)mm
Examination Code :	ASME V	No of Radiograph(exposure) :	Single Exposure
Acceptance Code:	ASME Sect. VIII Div.1 : 2017 Ed.	No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
Examination Date:	14 April 2018	Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
Sludge Filter No.1 (222/001/1)								
Joint 3 (WN-119)					6	0 - 1 Por	Reject	
						1 - 2 Inc	Reject	
						2 - 3 Por	Reject	
						3 - 4 NRI	Accept	
						4 - 5 AR	Reshoot	
						5 - 6 Por	Accept	
						6 - 7 Por / Uc	Visual	
						7 - 8 Por / SI	Reject	
						8 - 9 Por / Uc	Accept	
						9 - 10 Por / Uc	Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev. II

Date: 15 April 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103519/18-09

Page No: 2 of 2
 Report No: NDT/RT/180405-01/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
-------------------------------	------------	------------	--------------------------	-------------------------------	------------------	---------------------	--------	---------

Sludge Filter No.1 (222/001/1)

Joint 3 (WN-119)	9	3	-	6	10 - 11	Por	Reject		
					11 - 12	Uc			Accept
					12 - 13	Por / LF			Reject
					13 - 14	Por			Reject
					14 - 15	SI			Reject
					15 - 16	Por			Reject

End of Report

