



Our Ref. : NT/103632/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-06/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D08								
WPS No. : YF-WPS-009								
LS4	13	3	-	10	0 - 1	Por	Accept	
YFW094					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	NRI	Accept	
					4 - 5	NRI	Accept	
					5 - 6	NRI	Accept	

\_\_\_\_\_ End of Report \_\_\_\_\_

**Legend:**

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II



Client Representative:

Name:



Our Ref. : NT/103832/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-07/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)	(mm)			
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D08								
WPS No. : YF-WPS-009								
LS2 YFW094	13	3	-	10	0 - 1	NRI	Accept	
					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	NRI	Accept	
					4 - 5	NRI	Accept	
					5 - 6	NRI	Accept	

End of Report

**Legend:**

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II



Client Representative:

Name:



Our Ref.: NT/103832/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-08/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D08								
WPS No. : YF-WPS-009								
LS3 YFW094	13	3	-	10	0-1 1-2 2-3 3-4 4-5	NRI NRI NRI NRI Por	Accept Accept Accept Accept Accept	AR

End of Report

#### Legend:

TI Tungsten Inclusion	NRI No Relevant Indication	Uc Undercut	Por Porosity	WT Weld Thickness
SI Slag Inclusion	LP Lack of Penetration	Con Concavity	BT Burn Through	RT Reinforcement Thickness
LF Lack of Fusion	EP Excess Penetration	AR Artifact	Sur Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 09 June 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103832/18-11

Page No: 1 of 1

Report No: NDT/RT/180684-09/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radlographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D07								
WPS No. : YF-WPS-009								
LS3 YFW094	13	3	-	10	0 - 1 1 - 2 2 - 3 3 - 4 4 - 5	Por NRI NRI NRI NRI	Accept Accept Accept Accept Accept	

End of Report

#### Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Name:

Date: 09 June 2018

Date:





Our Ref. : NT/103832/18-11

Page No: 1 of 1

Report No: NDT/RT/180684-10/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D07								
WPS No. : YF-WPS-009								
LS4 YFW094	13	3	-	10	0-1	Inc / Por		Reject
					1-2	NRI		Accept
					2-3	NRI		Accept
					3-4	NRI		Accept
					4-5	NRI		Accept
					5-6	Por		Accept

End of Report

#### Legend:

TI Tungsten Inclusion	NRI No Relevant Indication	Uc Undercut	Por Porosity	WT Weld Thickness
SI Slag Inclusion	LP Lack of Penetration	Con Concavity	BT Burn Through	RT Reinforcement Thickness
LF Lack of Fusion	EP Excess Penetration	AR Artifact	Sur Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 09 Jun 2018



Client Representative:

Name:

Date:



# NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103832/18-11

Page No: 1 of 1

Report No: NDT/RT/180684-11/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D07								
WPS No. : YF-WPS-009								
LS2	13	3	-	10	0 - 1	Por	Accept	
YFW094					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	Shadow		Reshoot
					4 - 5	NRI	Accept	
					5 - 6	NRI	Accept	

End of Report

### Legend:

TI Tungsten Inclusion	NRI No Relevant Indication	Uc Undercut	Por Porosity	WT Weld Thickness
SI Slag Inclusion	LP Lack of Penetration	Con Concavity	BT Burn Through	RT Reinforcement Thickness
LF Lack of Fusion	EP Excess Penetration	AR Artifact	Sur Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 09 June 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103832/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-03/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D06								
WPS No. : YF-WPS-009								
LS4	13	3	-	10	0 - 1	NRI	Accept	
YFW125					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	NRI	Accept	
					4 - 5	NRI	Accept	
					5 - 6	NRI	Accept	

End of Report

**Legend:**

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II



Client Representative:

Name:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103832/18-11

Page No: 1 of 1

Report No: NDT/RT/180684-04/18

### RADIOGRAPHIC EXAMINATION REPORT

#### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

#### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order :	P/18/019							
Drawing Number :	-							
Description :	Bleaching Vessel ID 2400 X 4500 TL-TL							
Serial No :	2803D06							
WPS No. :	YF-WPS-009							
LS2	13	3	-	10	0 - 1	NRI	Accept	
YFW125					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	NRI	Accept	
					4 - 5	NRI	Accept	
					5 - 6	Por	Accept	

End of Report

#### Legend:

TI Tungsten Inclusion	NRI No Relevant Indication	Uc Undercut	Por Porosity	WT Weld Thickness
SI Slag Inclusion	LP Lack of Penetration	Con. Concavity	BT Burn Through	RT Reinforcement Thickness
LF Lack of Fusion	EP Excess Penetration	AR Artifact	Sur. Surface	

#### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev. II



Client Representative:

Name:



# NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103832/18-11

Page No: 1 of 1

Report No: NDT/RT/180684-05/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	JJ Lurgi Engineering Sdn Bhd C294	IQI type :	ASTM 1B
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	FCAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Section VIII Div 1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(10+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSi
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : P/18/019								
Drawing Number : -								
Description : Bleaching Vessel ID 2400 X 4500 TL-TL								
Serial No : 2803D06								
WPS No. : YF-WPS-009								
LS3	13	3	-	10	0 - 1	NRI	Accept	
YFW125					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	
					3 - 4	Por	Accept	
					4 - 5	NRI	Accept	

End of Report

### Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con. : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II



Client Representative:

Name:



Our Ref. : NT/103832/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-02/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Fee ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	Greater Enfield Development	IQI type :	ASTM 1A
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(5+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : A/17/130-U Drawing Number : YF3057.029 Description : Instrument Air Dryer Serial No : U/18/0018 Tag No. : 55-V-6122B2	8	3	-	5	0 - 1	Sur	Visual	
CS2 YF060								

\_\_\_\_\_ End of Report \_\_\_\_\_

#### Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II  
 Interpreted & Evaluated By: Amat Hamidi - NDT Lev. II



Client Representative:

Name:

Date:



Our Ref. : NT/103832/18-11

Page No: 1 of 1  
 Report No: NDT/RT/180684-01/18

## RADIOGRAPHIC EXAMINATION REPORT

### Client and Testing Particulars

Client :	Yuen Foe ( Wan Soon ) Eng. Sdn Bhd	Procedure No:	NT/RT/ASME REV 7.0
Project :	Greater Enfield Development	IQI type :	ASTM 1A
Material:	Stainless Steel	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW	Density :	2.0-3.5
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Section VIII Div 1 : 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	08 June 2018	Source Side of Object to Film Distance:	(5+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

### Radiographic Examination Result

Weld Reference	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
Work Order : A/17/130-U								
Drawing Number : YF3057.029								
Description : Instrument Air Dryer								
Serial No : U/18/0016								
Tag No. : 55-V-6122A2								
CS2 YF060	8	3	-	5	0-1	NRI	Accept	

\_\_\_\_\_ End of Report \_\_\_\_\_

#### Legend:

TI Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

### Personnel Particulars

Radiographer : M.Zaffri - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 09 June 2018



Client Representative:

Name:

Date: